









**Electrical Equipment:**

- Extension cords shall be U.L. listed for their use, located so they do not present a tripping hazard and are placed out of foot traffic areas. Secure cords as necessary with tape or ties ( not under carpet).
- Single plug extension cords must be plugged directly into an approved receptacle and shall serve only one appliance/ device.
- Extension and appliance cords shall be in good condition without splices, deterioration, modification or damage.
- Extension cords may not be run in series (Daisy Chain). They must be plugged into a direct outlet.

**Fire Extinguishers:**

- Booths with cooking shall provide a minimum 2A-10BC rated fire extinguisher. If cooking activity is located outside booth, the 40BC extinguisher shall be in addition to the 2A-10BC required above. All extinguishers shall be certified for year of use and have a current CA State Fire Marshal certification tag attached.
- All extinguishers shall be visible and accessible at all times, preferably mounted near a point of egress.
- When a generator is used, one 40BC fire extinguisher must be located within 50 feet of the generator’s location and it must be readily accessible.

I acknowledge that I have read, understand, and agree to adhere by the Alameda County Fairgrounds-2022 California Fire Code. Authority having jurisdiction will be checking booths, during the duration of the Event. If you cannot abide by the above regulations and ensuring continued compliance, you will be asked to close your booth.

---

Company Name

First, Last Name

---

SIGNATURE OF AUTHORIZED REPRESENTATIVE

DATE